

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 7610-0253:100 Page 1 of 1

CATEGORY: Misc. Accessories

LISTEE: Gaylord Industries, PO Box 1149, Tualatin, OR 97062-1149
Contact: Philip O. Morton (800) 547-9696

DESIGN: Model QUENCHER Water Spray System. *Suitable as an attachment to the automatic sprinkler systems for protection of cooking equipment. Rated water flow pressure 40 psi minimum and 175 psi maximum. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model designation, working pressure and UL label.

APPROVAL: Listed as a fire sprinkler accessory device *for the protection of cooking equipment.
*QUENCHER Water Spray System must be attached to a wet-pipe sprinkler sytem.
Authority having jurisdiction should be consulted prior to installation.

NOTE: Formerly 7775-0253:100

Corrected 08-24-95



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **MARCH 26, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO, Supervising Deputy**

